



October 31, 2022

Huron, CA

Re: Lead & Copper Sample Results

The City would like to thank you for your assistance in helping us complete the required Lead & Copper Monitoring, to comply with the California Division of Drinking Water and Federal Environmental Protection Agency (EPA) Lead & Copper Rule.

We are happy to inform you the test results for your sample you provided to us meet the standard limits set by the EPA.

Your results are as follows: **Note mg/l = Parts per Million**

Lead Limit mg/l	Your Lead Sample Result mg/l	Copper Limit mg/l	Your Copper Sample Result mg/l
0.15	None Detected	1.3	None Detected

Again, thank you for your time and assistance in this water sampling process. If you have any question regarding this mater, you can reach me at 775 781-6758.

Sincerely,

Dennis Longhofer
Public Works Director